

International Standard



7077

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Measuring methods for building – General principles and procedures for the verification of dimensional compliance

Méthodes de mesurage pour la construction – Principes généraux pour la vérification de la conformité dimensionnelle

First edition – 1981-10-01

STANDARDSISO.COM : Click to view the full PDF of ISO 7077:1981

UDC 69 : 621.753.1 : 531.7.08

Ref. No. ISO 7077-1981 (E)

Descriptors : construction, buildings, measurement, dimensional measurement, measuring techniques, generalities.

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards institutes (ISO member bodies). The work of developing International Standards is carried out through ISO technical committees. Every member body interested in a subject for which a technical committee has been set up has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council.

International Standard ISO 7077 was developed by Technical Committee ISO/TC 59, *Building construction*, and was circulated to the member bodies in April 1980.

It has been approved by the member bodies of the following countries :

Australia	Finland	Korea, Rep. of
Belgium	France	Norway
Brazil	Germany, F. R.	Poland
Bulgaria	Hungary	Romania
Cuba	India	South Africa, Rep. of
Cyprus	Ireland	Spain
Czechoslovakia	Israel	Sweden
Denmark	Italy	United Kingdom
Egypt, Arab Rep. of	Japan	Yugoslavia

The member body of the following country expressed disapproval of the document on technical grounds :

Netherlands

Measuring methods for building – General principles and procedures for the verification of dimensional compliance

0 Introduction

International Standards dealing with the application of these principles are currently being prepared.

1 Scope

This International Standard indicates the principles to be applied for carrying out dimensional compliance control measurements in building construction. It deals with compliance measurements for setting out component manufacture and assembly, and the building as a whole.

2 Field of application

This International Standard applies to all types of building construction.

3 References

ISO 1803, *Tolerances for building – Vocabulary*.¹⁾

ISO 4463, *Measurement methods in building – Setting out and measurement – Permissible deviations*.

ISO 4464, *Tolerances for building – Relationship between the different types of deviation*.

4 Definitions

4.1 compliance measurement : Measurement carried out to verify compliance with the specified permitted deviation of a completed stage of the construction process (for example, building components, setting out and constructed work).

NOTE — Compliance measurements are not synonymous with informal check measurements as defined in ISO 4463.

4.2 measurement accuracy check : Set of measurements carried out to check the accuracy of a compliance measuring method.

1) At present at the stage of draft. (Revision of ISO 1803-1973.)

2) For economical reasons it may be convenient to decide which are the important dimensions to be specified.

5 General

5.1 Compliance measurements for the operation of setting out the location of the building (or other projects) as a whole are carried out to confirm the relationship between the building and the physical features in the immediate environment.

Compliance measurements for all other operations including setting out within the building are carried out to verify compliance with the specified permitted deviation.

5.2 The following items shall be listed in the inspection schedule :

- a) all operations to be subjected to compliance measurements;
- b) information about the time of these measurements;
- c) information about the physical reference conditions;
- d) description and details of methods of measurements;
- e) any other matters pertaining to compliance measurements.

5.3 The list of items given in the inspection schedule should not prevent the addition of other operations if it should prove necessary to obtain compliance measurements of them.²⁾

6 Procedures

6.1 Accuracy of compliance measurements

When carrying out compliance measurements, it is necessary to ensure that the measurement procedure will give a sufficiently accurate result.

6.1.1 For all operations within the building, the compliance measurements should be significantly more accurate than the specified permitted deviations of the operation to be checked.

NOTE — The actual value chosen depends on technical and economical factors and should be given in the verification schedule. Generally the standard deviation inherent to the measuring procedure should be of the order of 1/10 of the specified permitted deviation i.e. 2,5 times the standard deviation inherent to the measuring procedure should be of the order of 0,25 times the specified permitted deviation.