

NFPA 312

Fire Protection of Vessels During Construction, Repair, and Lay-Up 1990 Edition



NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on the procedures for requesting Technical Committees to issue Formal Interpretations, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

A statement, written or oral, that is not processed in accordance with Section 16 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Users of this document should consult applicable Federal, State and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action which is not in compliance with applicable laws and this document may not be construed as doing so.

Policy Adopted by NFPA Board of Directors on December 3, 1982

The Board of Directors reaffirms that the National Fire Protection Association recognizes that the toxicity of the products of combustion is an important factor in the loss of life from fire. NFPA has dealt with that subject in its technical committee documents for many years.

There is a concern that the growing use of synthetic materials may produce more or additional toxic products of combustion in a fire environment. The Board has, therefore, asked all NFPA technical committees to review the documents for which they are responsible to be sure that the documents respond to this current concern. To assist the committees in meeting this request, the Board has appointed an advisory committee to provide specific guidance to the technical committees on questions relating to assessing the hazards of the products of combustion.

Licensing Provision — This document is copyrighted by the National Fire Protection Association (NFPA).

1. Adoption by Reference — Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription — **A.** Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rulemaking process. **B.** Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rulemaking powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rulemaking powers may apply for and may receive a special royalty when the public interest will be served thereby.

3. Scope of License Grant — The terms and conditions set forth above do not extend to the index to this document.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

Copyright © 1990 NFPA, All Rights Reserved

NFPA 312
Standard for
Fire Protection of Vessels during
Construction, Repair, and Lay-Up
1990 Edition

This edition of NFPA 312, *Standard for Fire Protection of Vessels during Construction, Repair, and Lay-Up*, was prepared by the Technical Committee on Shipbuilding, Repair and Lay-Up, released by the Correlating Committee on Marine Fire Protection, and acted on by the National Fire Protection Association, Inc. at its Annual Meeting held May 21-24, 1990 in San Antonio, TX. It was issued by the Standards Council on July 20, 1990, with an effective date of August 17, 1990, and supersedes all previous editions.

The 1990 edition of this document has been approved by the American National Standards Institute.

Origin and Development of NFPA 312

The first standard on these subjects was adopted by the NFPA in 1933 on recommendation of its Marine Committee, predecessor of the Marine Section. It was further considered in 1935, 1936, and 1937 and was finally adopted by the Association in 1938 on recommendation of the Marine Section Committee on Builders' Risk, Repair and Lay-Up. Editorial changes were made in 1942.

With the reorganization of NFPA marine activities in 1948, responsibility for the standard fell to the Committee on Shipbuilding, Repair and Lay-Up. Their recommendations were adopted by the Association in 1950 (Parts I and II) and 1951 (Part III), and revised editions were adopted in 1964, 1968, 1976, and 1984.

The 1990 edition of NFPA 312 is a complete revision that incorporates expanded requirements for vessel lay-up and an update of the fire protection requirements for vessels undergoing construction, conversion, and repair.

Committee on Marine Fire Protection**Correlating Committee****Robert Loeser, Chairman**

Underwriters Laboratories Inc.

Richard A. Comstock, Fire Prev. & Engr. Bureau of
Texas**Joseph J. Cox**, American Inst. of Merchant Shipping**Bolling F. Douglas**, Marine Associates Inc.**Warren E. Jackson**, Glastonbury, CT**Technical Committee on Shipbuilding,
Repair and Lay-Up****Joseph J. Cox, Chairman**

American Inst. of Merchant Shipping

David E. Ezzell, Newport News Shipbuilding
& Dry Dock Co.**John P. Goudreau**, Wormald Fire Systems, Inc.
Rep FEMA**Edward S. Karlson**, U.S. Maritime Administration**David H. Kay**, U.S. Dept. of the Navy**Donald J. Kerlin**, Dept. of Transportation**Richard H. Nelson**, Coral Springs Medical Center**Donald Reilly**, M&M Protection Consultants**Winston A. Smith**, Norshipco**Elias J. Swerida**, Wall Fire Dept., NJ

Rep FMANA

Louis G. Tonti, NKF Engineering Inc.**John W. VanBrunt**, Bricktown, NJ**William A. Webb**, Rolf Jensen & Assoc. Inc.**Alternates****James A. Hill**, Naval Sea Systems Command
(Alternate to D. H. Kay)**Alan L. Schneider**, U.S. Coast Guard
(Alternate to D. J. Kerlin)**Nonvoting****Basil A. Needham, Jr.**, U.S. Dept. of Labor OSHA**Ronald L. Signorino**, U.S. Dept. of Labor
(Alternate to B. A. Needham, Jr.)**Guy R. Colonna**, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

NOTE: Membership on a Committee shall not in and of itself constitute an endorsement of the Association or any document developed by the Committee on which the member serves.

Contents

Chapter 1 Introduction	312- 5
1-1 Scope.	312- 5
1-2 Definitions.	312- 5
Chapter 2 Construction, Conversion, and Repair	312- 5
2-1 Inspection.	312- 5
2-2 Rubbish, Waste Materials, Oil Spills, and General Care.	312- 6
2-3 Smoking.	312- 6
2-4 Storage of Explosives, Flammable Material, and Dangerous Cargo.	312- 6
2-5 Use of Open Flame or Spark-Emitting Devices.	312- 7
2-6 Temporary Electrical Installations.	312- 7
2-7 Application of Paints and Other Flammable Compounds.	312- 7
2-8 Protection to Door Openings.	312- 7
2-9 Staging and Miscellaneous Structures.	312- 7
2-10 Watch Service.	312- 7
2-11 Fire Alarm Service.	312- 8
2-12 Fire Protection Equipment.	312- 8
2-13 Fire Brigade.	312- 8
2-14 Vessel Stability during Fire Fighting.	312- 8
Chapter 3 Lay-Up	312- 8
3-1 Application.	312- 8
3-2 Governmental Authorities.	312- 9
3-3 General Considerations for Lay-Up Locations.	312- 9
3-4 Lay-Up Berths at Dock.	312- 9
3-5 Vessel Preparation.	312- 9
3-6 Power Source.	312- 9
3-7 Dehumidification.	312- 9
3-8 Planning and Station Bills.	312- 9
3-9 General Care and Cleanliness.	312-10
3-10 Ventilation — Closure of Openings.	312-10
3-11 Storage of Explosive and Flammable Materials.	312-10
3-12 Temporary Heating Arrangements.	312-10
3-13 Temporary Electrical Wiring.	312-10
3-14 Watches.	312-10
3-15 Fire Detection and Fire Alarms.	312-10
3-16 Fire Protection.	312-10
Chapter 4 Referenced Publications	312-11
Appendix A	312-11
Appendix B Referenced Publications	312-12
Index	312-12

NFPA 312**Standard for****Fire Protection of Vessels during
Construction, Repair, and Lay-Up****1990 Edition**

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates explanatory material on that paragraph in Appendix A.

Information on referenced publications can be found in Chapter 4 and Appendix B.

Chapter 1 Introduction

Due to the quantity and character of combustible materials used in the construction of many vessels, such vessels in course of construction, conversion, during repair, and while laid up in a shipyard or elsewhere are readily vulnerable to fire. Long passageways, unenclosed stairways, hatches, and hoistways facilitate the rapid spread of fire throughout the vessel. The location of the vessel is frequently so isolated that dependence for fire fighting is mainly on the private protection provided. Even where major municipal protection is available, the possible delayed response due either to lateness in the discovery of the fire or the absence of means for quick notification, lack of special equipment in many municipal fire departments for combating shipboard fires, or an unfamiliarity with ship construction due to the transitory nature of the risk may cause material damage or complete destruction before effective means of extinguishment can be brought into action. Therefore, every reasonable means of preventing fire shall be provided and supplemented by such means of detection and protection equipment as will permit the prompt discovery, retard the spread, and permit extinguishment of any fire before it has passed the incipient stage. This includes full coordination and cooperation with municipal fire departments.

1-1 Scope. This standard applies to vessels during the course of construction, conversion, repairs, or while laid up. It does not apply to situations where it is in conflict with or superseded by requirements of any government regulatory agency.

1-1.1 Emergency Exception. Nothing in this document shall be construed as prohibiting the immediate drydocking of a vessel whose safety is imperiled as by being in a sinking condition or by having been seriously damaged. In such cases, all necessary precautionary measures shall be taken as soon as practicable.

1-2 Definitions.

Approved. Acceptable to the "authority having jurisdiction."

NOTE: The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment, or materials nor does it approve or evaluate testing laboratories.

In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization concerned with product evaluations which is in a position to determine compliance with appropriate standards for the current production of listed items.

Authority Having Jurisdiction. The "authority having jurisdiction" is the organization, office or individual responsible for "approving" equipment, an installation or a procedure.

NOTE: The phrase "authority having jurisdiction" is used in NFPA documents in a broad manner since jurisdictions and "approval" agencies vary as do their responsibilities. Where public safety is primary, the "authority having jurisdiction" may be a federal, state, local or other regional department or individual such as a fire chief, fire marshal, chief of a fire prevention bureau, labor department, health department, building official, electrical inspector, or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the "authority having jurisdiction." In many circumstances the property owner or his designated agent assumes the role of the "authority having jurisdiction"; at government installations, the commanding officer or departmental official may be the "authority having jurisdiction."

Labeled. Equipment or materials to which has been attached a label, symbol or other identifying mark of an organization acceptable to the "authority having jurisdiction" and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

Listed. Equipment or materials included in a list published by an organization acceptable to the "authority having jurisdiction" and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

NOTE: The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The "authority having jurisdiction" should utilize the system employed by the listing organization to identify a listed product.

Shall. Indicates a mandatory requirement.

Should. Indicates a recommendation or that which is advised but not required.

Chapter 2 Construction, Conversion, and Repair**2-1 Inspection.**

2-1.1 Regular inspections shall be made by a responsible person representing the shipyard during the entire construction or repair period to note and initiate action to eliminate fire hazards or to implement work procedures to keep these hazards to a minimum.

2-1.2 As soon as practicable after a vessel enters a repair yard, but before any work is started, an inspection of the vessel shall be made by a yard representative to evaluate the potential fire hazard. It shall be made jointly with a representative of the owner, if available. Such inspection shall note housekeeping conditions, including location of dunnage and trash; the kind and amount of cargo aboard; and the type, amount, and condition of the vessel's fire protection equipment.

2-1.3 The types and approximate amounts of fuel oils and other flammable liquids in all cargo, bunker, deep, settler, and double bottom tanks shall be determined. Such determination shall include all associated piping systems.

2-1.4 The information obtained shall be distributed to the departments responsible for the firesafety of vessels while in the yard and to the various production departments involved.

2-1.5 For minor repairs, the inspection may be limited to the actual working area and adjacent compartments. Supplementary information necessary for fire and explosion prevention shall be obtained.

2-2 Rubbish, Waste Materials, Oil Spills, and General Care.

2-2.1 Work areas shall be kept clean. All accumulations, and particularly combustible rubbish, refuse, and waste materials, shall be collected and safely disposed of as they accumulate.

2-2.2 Uncrating of equipment or working materials shall be accomplished before taking the contents aboard a ship unless they can be damaged in handling, in which case the consignment can be taken aboard to be uncrated. All crating and packing material shall be removed immediately to a remote location ashore.

2-2.3 Protective coverings, such as tarpaulins, used to protect machinery and equipment shall be either noncombustible or fire retardant approved material.

2-3 Smoking. Smoking shall be prohibited in designated hazardous areas. "No Smoking" signs shall be prominently posted in all prohibited areas.

2-4 Storage of Explosives, Flammable Material, and Dangerous Cargo.

2-4.1* The storage of explosive, flammable, or combustible materials, excepting ship's fuel and standard ship's stores stowed in certified spaces, shall not be permitted on or in close proximity to vessels in course of construction or repair.

2-4.2 Vessels carrying explosives or other dangerous cargo such as flammable gases, hazardous chemicals, and flammable liquids, but excepting ship's fuel and storage in certified spaces, shall not be permitted to enter a repair yard until such materials have been removed. NFPA 306, *Standard for the Control of Gas Hazards on Vessels*, outlines the circumstances under which exceptions to this requirement may be exercised with respect to gas hazards.

2-5 Use of Open Flame or Spark-Emitting Devices.

2-5.1* It shall be the responsibility of yard management to determine that any hot work or other fire- or spark-producing operations may proceed with safety.

2-5.2 The opposite sides of the bulkheads or decks on which hot work is to be done shall be checked to be certain that there are no combustible materials, painted surfaces, wiring runways, etc., in contact with or in close proximity to such bulkheads or decks, which may be damaged by heat or fire. Where there is any danger of starting fires in the way of hot work, despite the fact that ordinary precautions are employed, a fire watch shall be provided to stand by during such operations with suitable portable fire fighting equipment ready to extinguish any incipient fire that may occur. The employees acting as the fire watch shall be instructed as to the fire hazards anticipated and how to use the fire extinguishing equipment provided.

2-5.2.1 When it is necessary to remove combustible insulation to a safe distance from the location where welding or burning is to be done, special care shall be taken to prevent sparks or hot slag from entering exposed insulated spaces. Doorways, hatch and tank openings, portholes, etc., shall be protected where there is a danger of sparks or hot slag dropping or ricocheting into such openings and igniting combustible materials. Hot work shall not be done on vessels where there is a danger of sparks or hot slag falling into oil slicks on the waters beneath.

2-5.2.2 Where hot work processes cannot be properly safeguarded in making necessary repairs, such repairs shall be accomplished by safer means, such as by drilling, sawing, bolting, or other appropriate means.

2-5.3 Riveting furnaces shall not be permitted in confined spaces or in close proximity to combustible materials.

2-5.4* Before any hot work involving riveting, welding, burning, heating, or other fire- or spark-producing operations is started in or on any fuel spaces or other areas that contain or have contained flammable or combustible liquids or vapors, certification shall be obtained in accordance with NFPA 306, *Standard for the Control of Gas Hazards on Vessels*.

2-5.5 Equipment such as blow torches and cutting and welding apparatus shall be so stored as to prevent tampering by unauthorized persons. Oxygen, acetylene, and other flammable gas lines shall be disconnected at the source of supply at the end of each working shift, and the discharge end of the hose removed from below decks or enclosed spaces. During meal periods or other extended nonwork periods, lines shall be disconnected at the source of supply.

2-5.5.1 Only oxygen, acetylene, and other flammable gas hose in good repair shall be used. Where gases are supplied from portable cylinders, the portable cylinders shall not be placed below the main deck, in confined spaces, or under overhanging decks. Portable outlet headers from piped systems shall comply with the provisions of NFPA 51B, *Standard for Fire Prevention in Use of Cutting and Welding Processes*.

2-5.6 Electric welding cables shall be inspected frequently and cables with damaged insulation shall be reinsulated or replaced. Cables shall be triced-up off steel decks, bulkheads, or wherever possible to reduce the possibility of short-circuiting or grounding. Where cables must be run in areas of personnel or vehicular traffic, suitable protection shall be provided to prevent crushing of the cables. When not in use, electrodes shall be removed from holders and the holders so placed that they will not cause arcing or electrical short circuits.

2-5.7 Vessels in drydock shall be suitably grounded.

2-5.8* Heating for the personal comfort of employees or for other reasons shall be done by means of steam, hot water, or electricity, using the vessel's heating facilities as far as practicable. Where salamanders must be used, they shall be mounted on 4-in. (102-mm) legs and shall be permitted only where someone is constantly in attendance. They shall be located a safe distance from combustible materials and so arranged as to avoid any danger of upset. Use of wood kindling fuel shall not be permitted. Under no conditions shall compressed air or oxygen be discharged into salamanders to increase the rate of burning.

2-5.9 Temporary, appropriately worded danger markings or warning signs shall be posted throughout vessels in course of construction or under repair wherever required.

2-6 Temporary Electrical Installations.

2-6.1 Electrical wiring and equipment of a temporary nature shall be substantially installed in such manner as to be safe from physical damage and be frequently inspected. Defects in wiring, fixtures, or equipment of a type liable to create dangerous conditions shall be promptly remedied. Portable equipment shall be grounded and provided with overcurrent protection and shall be disconnected when not in use.

2-6.1.1 When temporary wiring and equipment is needed in hazardous locations, such wiring and equipment shall conform to the provisions of Articles 500 through 503 of NFPA 70, *National Electrical Code*.®

2-6.2 Except where lights are required for inspection and safety purposes, electric current to the vessel's lighting system shall be cut off when no work is being done. All electric lines shall be kept triced-up off the decks wherever possible.

2-6.3 The vessel's permanent lighting system shall be used when conditions permit.

2-6.4 Where temporary, portable electric lights must be used, they shall be in accordance with NFPA 70, *National Electrical Code*.

2-6.5 Temporary electrical wiring shall be installed and maintained in a safe manner and shall be provided with overcurrent protection; installations in accordance with the provisions of Article 305 of NFPA 70, *National Electrical Code*, shall

constitute compliance with this requirement. Such wiring and lamps shall not be placed in direct contact with combustible materials. Makeshift hangers, such as nails, which might damage wiring insulations, shall not be used. Protective guards shall be installed on all lights subjected to physical damage.

2-7 Application of Paints and Other Flammable Compounds.

2-7.1 No welding, burning, or other open flames or spark-producing machines or operations such as chipping, grinding, etc., shall be permitted in close proximity to the application of flammable paints or other flammable compounds. Adequate ventilation shall be provided to maintain the atmosphere at not more than 10 percent of the lower explosive limit or below the lower limit of toxicity for that particular material, as determined by a certificated marine chemist. In all instances, precautions and application instructions of the manufacturer shall be obtained and observed. Monitoring of these areas shall be carried out by a designated competent person.

2-8 Protection to Door Openings.

2-8.1 As work advances, so far as practicable, all door openings shall be provided with permanent doors.

2-8.2* In order to minimize the spread of fire, all doors and personnel accesses shall be kept closed except as required by the work. All other openings, such as vent ducts, shall be kept closed wherever practicable.

2-8.3 Where doors are kept locked to prevent theft or unauthorized entry, the keys shall be made available to the guard and fire brigade or shall be located at a designated place aboard where they can be obtained without delay in emergencies by such personnel.

2-9 Staging and Miscellaneous Structures.

2-9.1* Staging other than metal or fire retardant treated wood shall be removed as soon as its purpose has been served.

2-9.2 Small buildings on or under shipways shall be restricted to those absolutely necessary and shall be of non-combustible construction.

2-10 Watch Service.

2-10.1 During the outfitting of new vessels, or in the case of vessels berthed for construction, conversion, or repair operations, a competent guard shall be on duty at all times when work is not in progress.

2-10.2 Where central station systems are not feasible or are not deemed necessary, an approved portable clock system shall be provided on the vessel during the outfitting, repair, or conversion period.

2-10.3 Watch service shall also be provided on the shipways during earlier stages of construction if a fire hazard exists due to completion of another vessel, combustibility of ways,

stocks, and staging, and any significant obstruction or congestion caused by the proximity of adjacent structures.

2-10.4 Before going on duty, guards shall be informed of locations where riveting, welding, burning, or other hot work has been carried on in the vicinity of combustible material during the previous work period. They shall also be advised of the locations of freshly painted areas, tanks containing oil, or other hazardous conditions. All such locations shall be inspected during the progress of work and as soon as practicable after work has been stopped. The regular watch force shall be assisted by other competent persons when necessary in order to complete the inspection within a reasonable period. The guards shall be required to give further special attention to these locations during their rounds so as to ensure against the spread of any previously undetected fires.

2-10.5 Guards shall be familiar with the location of all items of fire equipment on vessels, inspect them during their daily tours of inspection, and have knowledge of their use.

2-11 Fire Alarm Service.

2-11.1 A suitable means of alerting all persons aboard the vessel shall be provided and clearly identified. Instructions on what to do in case of fire shall be posted at points of vessel access.

2-11.2 Where central station or fire alarm supervised guard service is not provided, telephones shall be available at convenient locations on or near vessels and connected to a central office where someone is constantly on duty.

2-11.3 Provisions shall be made for the establishment, marking, and maintenance of proper fire lanes at ways and berths.

2-11.4 Ways, hulls, and berths shall be prominently identified. Yard layout diagrams shall be provided for public fire fighting whenever the yard is primarily dependent upon those facilities for fire protection.

2-12 Fire Protection Equipment.

2-12.1* Water with adequate pressure for fire extinguishing purposes shall be available to all parts of vessels in course of construction, conversion, and under repair. One-and-one-half-inch (38.1 mm) and 2½-in. (63.5 mm) lines of adequate length connected to shore hydrants for hose connections shall lead to points on vessels convenient for use in an emergency. Adequate supplies of spare hose and nozzles shall be readily available. Due regard shall be given to the capacity of existing shore hydrants to ensure that an adequate water supply is available.

2-12.2 Temporary pipe risers with hose connections supplied by shore lines shall be installed at the shipways, and a supply of hose shall be available at such connections on the various decks of vessels under construction. These risers shall be installed in the ratio of one for each 200 ft (62 m) of length of the vessel.

2-12.3* While vessels are at berths or in drydock, temporary hose lines supplied by shore connections shall be placed aboard the vessels connected and ready for use, in the ratio

of at least one hose line for each 200 ft (62 m) of length of vessel. Where this may be deemed unnecessary due to the size and type of vessel involved, hose lines shall be provided at the berthing spaces or drydocks.

2-12.4 Hose line connections or hydrants shall be provided with adapters to permit the connection of shore fire department hose.

2-12.5* On vessels under repair, the vessel's fire system piping shall be connected to water supplies from the yard by means of temporary shore to ship connections.

2-12.6 Hose lines or approved portable fire fighting and extinguishing appliances such as hand extinguishers, in suitable numbers for Class A, B, and C fires, shall be provided at convenient locations throughout vessels. Portable extinguishers shall be provided and used in accordance with NFPA 10, *Standard for Portable Fire Extinguishers*.

2-12.7 Alternate means shall be available for extinguishing Class A, Class B, and Class C fires that cannot be controlled by the limited capacity of portable hand extinguishers.

2-13* Fire Brigade. Designated employees shall form the nucleus of a fire brigade and shall be thoroughly drilled in the use of extinguishing equipment provided, including the laying of hose lines, the handling of hose streams and special extinguishing equipment, and the use of self-contained breathing apparatus. Drills shall be held at least once a month.

Exception: This does not apply where a shipyard fire department with paid members is maintained.

2-14 Vessel Stability during Fire Fighting.

2-14.1* After an outbreak of fire, at the first indication of lack of stability, the discharge of fire streams shall be reduced to the minimum necessary to prevent the spread of fire. Effective means to prevent capsizing of the vessel shall be taken as soon as the extent of the flooding indicates there may be danger of lack of stability.

2-14.2 On vessels under repair, the vessel's pumping facilities, or a shore substitute, shall be in condition and ready to free the bilges of water whenever it tends to accumulate. Scuppers leading from all decks below the main deck to the bilge shall be maintained free.

2-14.3 Provision shall be made for the withdrawal of any vessel in the event that fire makes withdrawal necessary.

Chapter 3 Lay-Up

3-1 Application.

3-1.1 This chapter applies to all vessels declared as laid up by the owner or operator, without a full crew, but with equipment either in operable condition or requiring a minimum

of work to restore it to service. This chapter does not apply to vessels in a long term inactive status ("mothballed"), requiring extensive work to return to active service or to vessels in a reduced operating status. It also does not apply to those vessels in routine shipyard maintenance availability (for example, two year drydock) or to those in emergency availability for repairs.

3-1.2 This chapter is primarily intended for large self-propelled vessels, although it is applicable to all other vessels to varying degrees. Where a vessel cannot satisfy a requirement either because of its design (barges typically do not have fire mains) or because the vessel is not required to have equipment or systems on board (not all vessels are required to have an International Shore Connection), it need not satisfy that requirement.

3-1.3 All repairs, reconstruction, conversion, and alteration (especially) performed during lay-up shall satisfy the requirements of Chapter 2 of this standard.

3-2 Governmental Authorities. Lay-up locations and procedures shall satisfy the current Coast Guard Captain of the Port requirements. All U.S. flag vessels that maintain their Certificate of Inspection shall continue to satisfy all applicable Coast Guard regulations.

3-3* General Considerations for Lay-Up Locations. The following factors shall be considered in choosing a lay-up site:

3-3.1 The location shall have sufficient water depth at all tidal stages year round to allow removal of the vessel in case of fire or other emergency.

3-3.2 The location shall be free of very low temperature extremes that would affect the fire main system and be free of excess humidity.

3-3.3 Depending on location, there shall be a fire alarm box, telephone, voice radio, or other reliable means of communication available.

3-3.4* Vessel moorings, whether the vessels are moored singly or in groups, shall be arranged to facilitate vessel movement in case of fire or other emergency.

3-3.5 Fenders or camels of ample size shall be provided alongside at areas of possible or actual contact with other vessels or land structures.

3-3.6* Towing craft and waterborne or land-based fire fighting assistance or both shall be available.

3-3.7 All anchors not already in use shall be available for emergency deployment.

3-3.8 The vessel's equipment shall be arranged so that personnel can part or slip the anchor chain.

3-4 Lay-Up Berths at Dock.

3-4.1 Where the lay-up berth is adjacent to wharf, pier, or other land-connected structure, it shall be free from exposure to potential fire and explosion hazards and provide

ready access for fire fighting equipment. Piers shall satisfy the requirements of NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*.

3-4.2 Vessels shall be moored singly at the lay-up berth unless there is access for shore-based fire fighting and salvage equipment to the outboard nested vessels.

3-5 Vessel Preparation.

3-5.1 Sea Valves. Sea suction for fire mains intended for immediate use shall not be covered and shall be kept clear from fouling.

3-5.2 Escape Preparation. Tow wires (fire warps) shall be secured at the bow and stern of each vessel and paid out through suitable hawse pipes or chocks so that the free end of the wire is readily accessible to tug boats for towing purposes. NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*, contains specifications for fire warps.

3-6 Power Source.

3-6.1 There shall be a source of power that may be from land, from another vessel, or on the vessel for lighting, flooding alarms, fire fighting, fire detection systems, and bilge pumping through the ship. This source shall be maintained and be immediately available. The power source shall not be a battery.

3-6.2 Where the service or emergency source of power is a portable generator set located on the weather deck, selection and placement shall take into account firesafety considerations of the fuel system, exhaust system, fire fighting systems, weather protection, and electrical installation and electrical protection devices.

3-7 Dehumidification. If the vessel is dehumidified for protection against corrosion, openings shall not be cut in any fire rated boundary unless the penetration is protected as required by U.S. Coast Guard and Safety of Life at Sea regulations, as applicable. In particular, combustible pipe and ducting can only be used where regulations allow and with the required protection.

3-8 Planning and Station Bills.

3-8.1 There shall be standard and emergency communication plans between vessel and shore.

3-8.2 There shall be contingency plans for fire fighting (including coordination with local fire departments), heavy weather, use of tug boats, moving the vessel, and emergency evacuation of personnel.

3-8.3 Fire station bill must be conspicuously posted for all personnel on the vessel, and safety observers for each work party shall be identified. Personnel shall be trained to perform their safety and emergency duties.

3-8.4 Fire control plans showing general arrangements, fire fighting equipment (including clear indication of which systems are operational), fire detection systems, ventilation systems, fire resistant boundaries, and means of escape shall be available in a prominently marked weathertight enclosure outside the deckhouse.

3-9 General Care and Cleanliness.

3-9.1 Vessels laid up shall be kept thoroughly clean throughout. Any accumulations, particularly combustible rubbish, refuse, and waste material, shall be collected and disposed of promptly.

3-9.2 Galley exhaust grease traps shall be cleaned prior to lay-up. If in use by watch personnel, the traps shall be inspected at least monthly and cleaned as necessary.

3-9.3 Smoking shall be prohibited aboard laid up vessels except at locations specifically designated and approved as smoking areas.

3-9.4 Protective coverings, such as tarpaulins, used to protect machinery and equipment shall be either noncombustible or fire retardant approved material.

3-9.5 All liquid and gaseous cargoes shall be offloaded from the vessel, and all vessels shall be certified in accordance with NFPA 306, *Standard for the Control of Gas Hazards on Vessels*, immediately prior to being laid up and weekly thereafter until conditions are stabilized, subject to requirements of regulatory authorities.

3-9.6 Machinery space bilges shall be clear of all debris, oil, and other flammable materials.

3-10 Ventilation — Closure of Openings.

3-10.1 All spaces, except those under dehumidification, accommodation spaces that are sealed, and cargo and ship service tanks, shall be ventilated and accessible for ready inspection.

3-10.2 All double bottom, deep, peak, settling, day, and all other miscellaneous tanks used for the vessel's fuel oil and lubricants shall have their manhole cover plates closed and secured and all exterior traces of oil or lubricants removed.

3-10.3 All vents serving tanks used for the vessel's fuel and lubricants, and all vents serving adjacent cofferdams, shall be fitted with flame screens or flame arresters, as appropriate, and left open.

3-10.4 Except where required for distribution of humidified air, all closures, including fire dampers (but not automatic fire dampers), in ventilation systems shall be closed. All automatic fire dampers shall be maintained in operating condition.

3-10.5 All ports, doors, and other openings in the vessel's shell or deck houses, and all hatches except those used for ventilation and access to holds, shall be kept closed, covered, or sealed. All interior doors shall be kept closed.

3-11* Storage of Explosive and Flammable Materials.

3-11.1 Explosives, flammable gases, hazardous chemicals, and flammable liquids, other than ship's fuel, shall not be retained aboard vessels if the lay-up is intended to exceed 60 days.

3-11.2 Fuel shall be drained from tanks and fuel systems of auxiliary motor craft and removed from the vessel if lay-up is intended to exceed 60 days.

3-11.3 When fuel is transferred, unless the fueling system is hard piped, the tank, hose, and machinery shall be bonded.

3-12 Temporary Heating Arrangements. Open flame heaters are prohibited. Temporary heating sources shall be disconnected when the vessel is unattended. When heat tracing cable is used in hazardous areas, a ground fault circuit interruption device shall be used in conjunction with the overcurrent device.

3-13 Temporary Electrical Wiring.

3-13.1 Electrical wiring for temporary use shall comply with the requirements of 2-6.1.

3-13.2 Portable electrical equipment shall be the double insulated type or provided with a grounding conductor in the supply cable and disconnected when not in use.

3-14 Watches.

3-14.1 There shall be a watch maintained whenever there is no functioning automatic fire detection and alarm system.

3-14.2 Watch service shall be established to monitor the vessel's condition and to detect unauthorized access.

3-14.3 The watch personnel shall be capable of performing emergency procedures, operating fire protection equipment, and assisting in removing the vessel from the lay-up location. Oxygen breathing apparatus or similar device shall be provided and maintained for immediate use.

3-14.4 The watch service shall be equipped for and satisfy the requirements of 2-10.5.

3-15 Fire Detection and Fire Alarms.

3-15.1 Where automatic fire detection and fire alarm systems are not installed or operable, the requirements of 2-11 shall be satisfied.

3-15.2 Vessels shall maintain the capability of two-way voice radio or telephone emergency communication. Portable radios satisfy this requirement.

3-15.3 If fire detection and fire alarm equipment is installed in lieu of the requirements of 3-14, it shall be capable of notifying appropriate personnel.

3-16 Fire Protection.

3-16.1 Access. Gangways, ladders, or other facilities providing access to the vessel or vessels for fire fighting purposes shall be available at all times.

3-16.2 Vessel Stability. The applicable requirements of 2-14 shall be satisfied in the event of fire.

3-16.3 Fire Protection Equipment. If any vessel fire protection system is intended to be used for fire protection it shall be maintained.

Chapter 4 Referenced Publications

4-1 The following documents or portions thereof are referenced within this standard and shall be considered part of the requirements of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

4-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 51B-1989, *Standard for Fire Prevention in Use of Cutting and Welding Processes*

NFPA 70-1990, *National Electrical Code®*

NFPA 306-1988, *Standard for the Control of Gas Hazards on Vessels*

NFPA 307-1990, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves.*

Appendix A

This Appendix is not a part of the requirements of this NFPA document, but is included for information purposes only.

A-2-4.1 Flammable and inflammable have the same meaning. The term "flammable liquids" in this instance includes all flammable and combustible liquids having a flash point below 140°F (60°C) closed cup test. Reference OSHA regulations for this definition.

A-2-5.1 Special attention is called to the danger of hot work in freshly painted areas, in close proximity to combustible stores or other materials, and similar locations.

A-2-5.4 Attention is called to the hazards of fuel in the tanks of motor driven life boats.

A-2-5.8 Attention is called to the need for adequate ventilation in confined spaces where salamanders are used.

A-2-8.2 Care should be taken that the closing of these openings is not obstructed or prevented by hose or pipe lines, electrical connections, or other lines. Provisions for disconnecting such lines should not be considered as a satisfactory alternative.

A-2-9.1 The use of combustible staging material should be carefully evaluated based on the nature of the work and the surrounding conditions.

A-2-12.1 The minimum nozzle residual pressure should be 60 psi (4.14×10^5 Pa) at 100 gpm (6.3×10^{-3} m³/s). The minimum total flow should be 500 gpm (3.15×10^{-2} m³/s) for ships approximately 300 ft (93 m) in length, having small interior compartments such as small passenger vessels. The minimum total flow for larger ships having 2000 sq ft (186 m²) in area or smaller compartments should be 1000 gpm (6.3×10^{-2} m³/s). Ships, such as cargo ships, having compartments larger than 2000 sq ft (186 m²) should have at least 1500 gpm (9.45×10^{-2} m³/s) available. Ships having large cargo holds may require higher capacities.

A-2-12.3 The hose lines should be nominal 1½ in. (38.1 mm) or 2½ in. (63.5 mm) in size, or a combination of both sizes, and of sufficient length so that any part of the vessel may be reached by at least one line.

A-2-12.5 Caution should be used in turning on these water supplies at shore connections until it is determined that the vessel's fire system is intact and will not result in flooding any portion of the vessel.

A-2-13 For further details, refer to NFPA 600, *Recommendations for Organization, Training and Equipment of Private Fire Brigades.*

A-2-14.1 In locations where carbon dioxide gas or other effective gas is readily available in adequate quantities, this medium of extinguishment should be employed when practicable in order that the vessel's stability not be endangered.

A-3-3 In addition to the fire related considerations for selecting a site for lay-up, the following general safety guidelines should also be considered: protection from open seas and surge; good holding ground for anchors, clear of wrecks, cables, or other obstacles; clear of known cyclone or tidal wave danger; clear of open roadstead anchorages or shipping channels; clear of high velocity or turbulent tidal or river currents; clear of floating hazards or significant amounts of moving ice; clear of hazardous shore facilities; and clear of industrial waste discharges.

A-3-3.4 The following guidelines should be considered when mooring vessels: the number, size, arrangement, and condition of the mooring lines shall be sufficient to hold the vessel secure, based on the vessel's freeboard and draft, and the extreme climatic, tidal, and current conditions in the area.

For vessels at anchorage the following guidelines should be considered: the size and scope of anchor chain and number and size of anchors shall be based on the freeboard, depth of water, type of bottom, and extreme climatic, tidal, and current conditions in the area.

A-3-3.6 The fire risk, proximity to port facilities, and location (relative to the pier or waterway) should be considered when determining the reasonable distance and time for availability of assistance.

A-3-11 Flammable and inflammable have the same meaning. The term "flammable liquids" in this instance includes all flammable liquids having a flash point below 80°F (26.6°C) closed cup and having a vapor pressure not

exceeding 40 psi absolute (2068.6 mm Hg) at 80°F (26.6°C). Reference Coast Guard regulations for this definition.

Appendix B Referenced Publications

B-1 The following documents or portions thereof are referenced within this standard for informational purposes only and thus are not considered part of the requirements of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

B-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10-1990, *Standard for Portable Fire Extinguishers*

NFPA 600-1986, *Recommendations for Organization, Training, and Equipment of Private Fire Brigades.*

B-1.2 Other Publications.

B-1.2.1 U.S. Government Publications. USGPO Superintendent of Documents, Washington DC 20402

Code of Federal Regulations

33 CFR

46 CFR

49 CFR

29 CFR Part 1915.

B-1.2.2 American Bureau of Shipping. ABS, 45 Eisenhower Dr., Paramus, NJ 07652

"Guide for Lay-Up and for Reactivation of Laid-up Ships" 1986.

Index

©1990 National Fire Protection Association, All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document which it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of the National Fire Protection Association, Inc.

<p>-A-</p> <p>Access</p> <p>Fire fighting 3-16.1</p> <p>Unauthorized 3-14.2</p> <p>Alarm service 2-11, 3-15</p> <p>Anchors 3-3.7, 3-3.8</p>	<p>Locked 2-8.3</p> <p>Permanent 2-8.1</p>
<p>-B-</p> <p>Berths, lay-up 3-4</p> <p>Bilges, machinery space 3-9.6</p> <p>Bills, planning and station 3-8</p>	<p>-E-</p> <p>Electrical equipment, portable 2-6.1, 3-13.2</p> <p>Electrical installations</p> <p>Power sources 3-16</p> <p>Temporary 2-6, 3-13</p> <p>Emergency exception 1-1.1</p> <p>Explosives</p> <p>Storage 2-4, 3-11, A-2-4.1, A-3-11</p> <p>Vessels carrying 2-4.2</p> <p>Extinguishers, portable fire 2-12.6, 2-12.7</p>
<p>-C-</p> <p>Cables</p> <p>Electric welding 2-5.6</p> <p>Heat tracing 3-12</p> <p>Camels 3-3.5</p> <p>Care, general 3-9</p> <p>Certification, hot work 2-5.4, A-2-5.4</p> <p>Cleanliness 3-9</p> <p>Communications 2-11.2, 3-3.3, 3-8.1, 3-15.2</p> <p>Construction of vessel Chap. 2</p> <p>Cylinders 2-5.5.1</p>	<p>-F-</p> <p>Fenders 3-3.5</p> <p>Fire brigade 2-13, A-2-13</p> <p>Fire department, cooperation with Chap. 1</p> <p>Fire detection 3-15</p> <p>Fire fighting</p> <p>Contingency plans 3-8.2</p> <p>Vessel stability 2-14, A-2-14.1</p> <p>Fire lanes, at ways and berths 2-11.3</p> <p>Fire protection 3-16</p> <p>Fire protection equipment</p> <p>Periodic inspection 2-10.5</p> <p>Maintenance 3-16.3</p> <p>Vessels under construction or repair 2-12, A-2-12</p> <p>Firewatch see Watch service</p> <p>Flammable compounds 2-7</p> <p>Hot work near 2-7.1</p> <p>Flammable gases 2-5.5.1, 3-11.1</p> <p>Flammable liquids 2-4.1, A-2-4.1</p> <p>Inspection 2-1.3</p> <p>Storage 3-11.1, A-3-11</p>
<p>-D-</p> <p>Dampers, fire 3-10.4</p> <p>Dangerous Cargoes</p> <p>Offloading 3-9.5</p> <p>Storage 2-4, A-2-4.1</p> <p>Vessels carrying 2-4.2</p> <p>Dehumidification 3-7</p> <p>Diagrams, yard layout 2-11.4</p> <p>Door Openings see Openings, door</p> <p>Doors</p> <p>Closed 2-8.2, 3-10.5</p>	

Flammable materials, storage of . 2-1.3, 2-4, 3-11, A-2-4.1, A-3-11
Fuels
 Inspection 2-1.3
 Removal 3-11.2
 Transferring 3-11.3
Furnaces, riveting 2-5.3

-G-

Generators, portable 3-6.2
Governmental authorities 3-2, 3-7
Grounding
 Portable electric equipment 2-6.1, 3-13.2
 Vessels in drydock 2-5.7
Guards see Watch service

-H-

Hatches 3-10.5
Hazardous locations, wiring and equipment 2-6.1.1
Heating
 During construction or repair 2-5.8, A-2-5.8
 During lay-up 3-12
 Temporary 3-12
Hose, flammable gas 2-5.5.1
Hose connections 2-12.1 thru 2-12.5, A-2-12.1, A-2-12.5
Hose lines 2-12.2, 2-12.3, 2-12.6, A-2-12.3
Hot work 2-5.1 thru 2-5.3, A-2-5.1
 Certification 2-5.4, A-2-5.4.
 Guarding 2-5.2, 2-10.4
 Near flammable paints or compounds 2-7.1
Hydrants, shore 2-12.1, 2-12.4, A-2-12.1

-I-

Inspection
 During construction or repair 2-1, 2-10.4
 During lay-up 3-10.1
 Fire equipment 2-10.5
Insulation
 Cable 2-5.6
 Combustible, removal to safe distance 2-5.2.1

-K-

Keys 2-8.3

-L-

Lay-Up Chap. 3
 Application 3-1
 Governmental authorities 3-2
 Location 3-2, 3-3, A-3-3
Lighting system 2-6.2, 2-6.3
Lights, portable electric 2-6.4, 2-6.5
Location of vessel Chap. 1

-M-

Moorings 3-3.4, 3-4.2, A-3-3-4

-O-

Oil spills 2-2
Open flame devices 2-5, 2-7.1, A-2-5
Openings
 Closure of 3-10
 Door, protection to 2-8, A-2-8.2

-P-

Paints
 Application of 2-7
 Hot work near 2-7.1
Piers 3-4.1
Plans
 Fire control 3-8.4
 Posting of 3-8
Power sources 3-6
Protective coverings 2-2.3, 3-9.4
Pumping facilities, vessel 2-14.2

-R-

Repair to vessel Chap. 2
 Minor 2-1.5
Response to fire Chap. 1
Risers, pipe 2-12.2
Riveting 2-5.3, 2-10.4
Rubbish 2-2, 3-9.1

-S-

Salamanders 2-5.8, A-2-5.8
Scope of standard 1-1
Security 2-8.3; see also Watch service
Smoking 2-3, 3-9.3
Spark-emitting devices 2-5, 2-7.1, A-2-5
Stability see Vessels, stability
Staging 2-9, A-2-9.1
Storage
 Explosives, flammable materials and
 dangerous cargoes 2-1.3, 2-4, 3-11, A-2-4.1, A-3-11
 Hotwork equipment 2-5.5
Structures, miscellaneous 2-9

-T-

Tanks, fuel and lubricant
 Closure of plates 3-10.2
 Vents 3-10.3
Telephones 2-11.2, 3-3.3
Tow wires 3-5.2
Towing craft 3-3.6, 3-5.2, A-3-3.6
Traps, galley exhaust grease 3-9.2

-U-

Uncrating of equipment 2-2.2

-V-

Valves, sea	3-5.1
Ventilation	
Confined spaces	A-2-5.8
In lay-up	3-10
Paint application areas	2-7.1
Vents, tank	3-10.3
Vessels	
In drydock, grounding	2-5.7
Preparation	3-5
Stability, during fire fighting	2-14, 3-16.2, A-2-14.1

-W-

Warning signs	2-5.9
Waste materials	2-2, 3-9.1
Watch service	
During construction or repair	2-10
During lay-up	3-14
For hot work	2-5.2, 2-10.4
Water supply, for fire protection	2-12.1, A-2-12.1
Wiring	see Electrical installations
Welding	see Hot work

SUBMITTING PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

**Contact NFPA Standards Administration for final date for receipt of proposals
on a specific document.**

INSTRUCTIONS

**Please use the forms which follow for submitting proposed amendments.
Use a separate form for each proposal.**

1. For each document on which you are proposing amendment indicate:
 - (a) The number and title of the document
 - (b) The specific section or paragraph.
2. Check the box indicating whether or not this proposal recommends new text, revised text, or to delete text.
3. In the space identified as "Proposal" include the wording you propose as new or revised text, or indicate if you wish to delete text.
4. In the space titled "Statement of Problem and Substantiation for Proposal" state the problem which will be resolved by your recommendation and give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If a statement is more than 200 words in length, the technical committee is authorized to abstract it for the Technical Committee Report.
5. Check the box indicating whether or not this proposal is original material, and if it is not, indicate source.
6. If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.
7. Type or print legibly in black ink.

NOTE: The NFPA Regulations Governing Committee Projects in Paragraph 10-10 state: Each proposal shall be submitted to the Council Secretary and shall include:

- (a) identification of the submitter and his affiliation (Committee, organization, company) where appropriate, and
- (b) identification of the document, paragraph of the document to which the proposal is directed, and
- (c) a statement of the problem and substantiation for the proposal, and
- (d) proposed text of proposal, including the wording to be added, revised (and how revised), or deleted.