

NFPA

703



FIRE RETARDANT IMPREGNATED WOOD AND FIRE RETARDANT COATINGS FOR BUILDING MATERIALS 1979



NATIONAL FIRE PROTECTION ASSN.
LIBRARY
470 ATLANTIC AVENUE
BOSTON, MASS. 02210

Copyright © 1979

All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION, INC.

470 Atlantic Avenue, Boston, MA 02210

4M-7-79-FP

Printed in U.S.A.

NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on obtaining Formal Interpretations of the document, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Assistant Vice President- Standards, National Fire Protection Association, 470 Atlantic Avenue, Boston, MA 02210.

Licensing Provision — This document is copyrighted by the National Fire Protection Association (NFPA).

1. Adoption by Reference — Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Assistant Vice President — Standards) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription — **A.** Public authorities with law-making or rule-making powers only, upon written notice to the NFPA (Attention: Assistant Vice President — Standards), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's law-making or rule-making process. **B.** Public authorities with advisory functions and all others desiring permission to reproduce this document or its contents in whole or in part in any form shall consult the NFPA.

All other rights, including the right to vend, are retained by NFPA.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

See Official NFPA Definitions at the back of this pamphlet.

© 1979 NFPA, All Rights Reserved

Standard for
Fire Retardant Impregnated Wood
and Fire Retardant Coatings for Building Materials

NFPA 703-1979

1979 Edition of NFPA 703

This 1979 edition of NFPA 703 was adopted by the National Fire Protection Association, Inc., on May 16, 1979 at its Annual Meeting in St. Louis, Missouri. It was released by the Standards Council for publication on June 11, 1979.

Origin and Development of NFPA 703

At a 1957 meeting in New York City, the Committee on Flameproofing and Preservative Treatments undertook to develop a Standard for Flameproofing of Wood. Since that meeting the Fire Retardant Coating Industry has expanded considerably, and it is obvious that fire retardant admixtures of plastics and other building materials will require coverage by standard. Thus, the Committee, in its many subsequent meetings, reexamined its approach and expanded the standard to cover all fire retardant treatments.

The first two chapters of the Standard for Fire Retardant Treatments of Building Materials have been developed. Chapter one deals with Fire Retardant Pressure-Impregnations and Chapter two with Fire Retardant Coatings. Both chapters were tentatively adopted by the 1960 Annual Meeting and both were submitted for final adoption at the 1961 Annual Meeting.

This 1979 edition of NFPA 703, *Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*, supersedes the previous 1961 edition. The change in title was necessary to more adequately cover the subjects included in the text of the standard. The principal changes in this 1979 edition include improved definitions for fire retardant coatings.

Committee on Building Construction

Correlating Committee on Building Construction

Donald W. Belles, *Chairman*

John R. Anderson, *Secretary**
National Fire Protection Association, Inc.

John L. Bryan*, University of Maryland,
Department of Fire Protection Engineering
John G. Degenkolb, Glendale, CA
George W. Flach* (Rep. National Electrical
Code Committee)
Harold E. Nelson, Center for Fire Research,
U.S. National Bureau of Standards

Chester W. Schirmer, Schirmer Engineering
Corp.

William A. Schmidt, Office of Construction
(08H) U. S. Veterans Administration

Richard H. Solomon, Naperville, IL

*Nonvoting

Technical Committee on Building Construction

Harold E. Nelson, *Chairman*,
Center for Fire Research, U.S. National Bureau of Standards

Louis E. Almgren, The FPE Group

C. R. Beauchamp, New England Telephone
Co. (Rep. NFPA Industrial Fire Protection
Section)

Roland Bellman, Rolf Jensen and Associates,
Inc.

Michael F. Burke, Factory Mutual Research
Corp.

Thomas E. Burke, Albert Kahn Associated,
Architects & Engineers

Herbert B. Carlsen, Gypsum Association

John P. Chleapas, Framingham Center, MA

William M. Connell, Port Authority of New
York (Rep. ANSI Committee on Safety Stan-
dards for Construction and Demolition)

William A. De Grow, Argonaut Realty Divi-
sion, General Motors Corporation.

William J. Downing, U.S. General Services
Administration

Cornelius Duffy Jr., Deputy Fire Marshal,
Westport Fire Department (Rep. Fire
Marshals Association of North America)

Dr. D. S. Ellifritt, Metal Building Manufac-
turers Association

Richard G. Gewain, American Iron & Steel
Institute

Christian Hansen, Insurance Services Office

Paul K. Heilstedt, Portland Cement Associ-
ation

Kenneth W. Howell, Underwriters Labora-
tories Inc.

Edwin B. Lancaster, Lancaster & Lancaster

Gerald E. Lingenfelter, American Insurance
Association

Donald T. Lyon, American Telephone &
Telegraph Company

E. E. Miller, Industrial Risk Insurers

G. L. Nelson, Plastics Division, General Elec-
tric Company (Rep. National Electrical
Manufacturers Association)

Alvin O. Peterson, Rogers, Lovelock & Fritz

John Ed Ryan, National Forest Products As-
sociation

Robert S. Strength, Monsanto Fire Safety
Center

E. M. Wetmore, Kemper Insurance Com-
panies (Rep. Alliance of American Insurers)

Alternates

James P. Barris , Portland Cement Assn. (Alternate to P. Heilstedt)	R. B. Buchan , National Forest Products Assn. (Alternate to J. E. Ryan)
Jack S. Barritt , Industrial Risk Insurers (Alternate to E. E. Miller)	Sanford Davis , U.S. National Bureau of Standards, Center for Fire Research (Alternate to H. E. Nelson)
William I. Blazek , General Services Administration (Alternate to W. J. Downing)	John L. Jablonsky , American Insurance Assn. (Alternate to G. E. Lingenfelter)
Delbert F. Boring, Jr. , American Iron & Steel Institute (Alternate to R. G. Gewain)	Herman H. Spaeth , Insurance Services Office (Alternate to C. Hansen)
David Brackett , Gypsum Assn. (Alternate to H. B. Carlsen)	Lyndon Welch , American Institute of Architects (Alternate to E. B. Lancaster)

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

Contents

Chapter 1 General	703-5
1-1 Scope	703-5
 Chapter 2 Fire Retardant Impregnated Wood	 703-5
2-1 Application	703-5
2-2 Definitions	703-5
2-3 General	703-6
2-4 Tests	703-6
2-5 Identification	703-6
 Chapter 3 Fire Retardant Coatings for Building Materials	 703-7
3-1 Application	703-7
3-2 Definitions	703-7
3-3 General	703-7
3-4 Tests	703-8
3-5 Maintenance of Protection	703-8
3-6 Identification	703-8
 Appendix A.	 703-9

Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials

NFPA 703-1979

Chapter 1 General

1-1 Scope. This standard provides criteria for defining and identifying fire retardant impregnated wood and fire retardant coated building materials.¹

Chapter 2 Fire Retardant Impregnated Wood

2-1 Application. These requirements apply to pressure impregnation treatments that reduce certain burning characteristics of wood. Other approved methods of impregnation, providing at least equal performance, are also acceptable.

2-2 Definitions.

2-2.1 Fire Retardant Impregnated Wood is lumber and plywood that has been impregnated by an approved process with fire retardant chemicals and demonstrates one of the following classes:

2-2.1.1 Fire Retardant Treated Wood is a special class of fire retardant impregnated wood that has a flame spread rating of 25 or less with no evidence of significant progressive combustion when tested for 30 minutes duration by the test listed in Section 2-4.

¹Fire resistance ratings measured on an hourly basis are not covered in this standard. To establish such ratings, tests should be made in accordance with NFPA 251, *Standard Methods of Fire Tests of Building Construction and Materials*:

2-2.1.2 Class A Fire Retardant Impregnated Wood has a flame spread rating of 25 or less when tested for 10 minutes duration by the test listed in Section 2-4.

2-2.1.3 Class B Fire Retardant Impregnated Wood has a flame spread rating of greater than 25 but not more than 75 when tested for 10 minutes duration by the test listed in Section 2-4.

2-3 General.

2-3.1 Where fire retardant impregnated wood is to be subjected to sustained humidity of 80 percent or more or exposure to the weather, certification by a testing laboratory must indicate that there is no increase in listed classification when subjected to the *Standard Rain Test* described in ASTM D-2898.

2-3.2 Fire retardant impregnated lumber and plywood shall be dried after treatment to a moisture content not to exceed 19 percent for lumber and 15 percent for plywood.

2-4 Tests. Fire retardant impregnated treated wood shall be tested by NFPA 255, *Method of Test of Surface Burning Characteristics of Building Materials* (U.L. 723, ASTM E-84).¹

2-5 Identification. Fire retardant impregnated lumber and plywood shall be labeled to indicate performance with the preceding requirements.

¹Under the criteria of NFPA 255, the flame spread rating is expressed numerically on a scale for which the zero point is fixed by the performance of asbestos-cement board and the 100 point is fixed by the performance of untreated red oak flooring.

Chapter 3 Fire Retardant Coatings for Building Materials

3-1 Application. These requirements apply to fire retardant coatings such as paints and other surface coatings used to reduce certain burning characteristics of building materials.

3-2 Definitions.

A **Fire Retardant Coating** is a coating that reduces the flame spread of Douglas Fir and all other tested combustible surfaces to which it is applied at least 50 percent or to a flame spread classification value of 75 or less, whichever is the lesser value, and has a smoke developed rating not exceeding 200.

A **Class A Fire Retardant Coating** shall, as applied to building materials, reduce the flame spread to 25 or less and have a smoke developed rating not exceeding 200.

A **Class B Fire Retardant Coating** shall, as applied to building materials, reduce the flame spread to greater than 25 but not more than 75 and have a smoke developed rating not exceeding 200.

3-3 General.

3-3.1 Fire retardant coatings shall remain stable and adhere under all atmospheric conditions to which the material is exposed.

3-3.2 A fire retardant coating shall not be used for unprotected outdoor installations unless labeled for such installations.

3-3.3 The classification of fire retardant coatings is applicable only when the coating is applied at the rates of coverage and to the type or kind of surfaces indicated on the test report when the coating is applied in accordance with the directions supplied by the manufacturer with the container.

3-3.4 These coatings shall be applied in accordance with the manufacturer's direction.

3-3.5 The authority having jurisdiction may require that the application be certified by the applicator as being in conformance with the manufacturer's direction for application.

3-3.6 Fire retardant coating shall not be overcoated with any coating unless both the fire retardant coating and the overcoat have been tested as a system and are found to meet the requirements of Section 3-2.

3-4 Tests.

3-4.1 Fire retardant coatings shall be tested by NFPA 255, *Method of Test of Surface Burning Characteristics of Building Materials* (U.L. 723, ASTM E-84).¹

3-4.2 Where fire retardant coatings are to be subjected to sustained humidity of 80 percent or more or exposure to the weather, certification by a testing laboratory must indicate that there is no increase in listed classification when subject to the *Standard Rain Test* described in ASTM D-2898.

3-5 Maintenance of Protection. Fire retardant coatings shall possess the desired degree of permanency and shall be maintained so as to retain the effectiveness of the treatment under the service conditions encountered in actual use.

3-6 Identification.

3-6.1 Each container of fire retardant coating material shall be labeled to indicate conformance with the preceding requirements and shall include the manufacturer's instructions for application.

¹The flame spread rating is expressed numerically on a scale for which the zero point is fixed by the performance of asbestos-cement board and the 100 point is fixed by the performance of red oak flooring.

Appendix A

This Appendix is not part of this NFPA Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials, NFPA 703, but is included for information purposes only.

A-1 NFPA Standards.

NFPA 251-1979, *Standard Methods of Fire Tests of Building Construction and Materials.*

NFPA 255-1979, *Method of Test of Surface Burning Characteristics of Building Materials.*

A-2 ASTM Publications.

ASTM D-2898-1977, *Standard Rain Test.*

ASTM E-84-1977, *Surface Burning Characteristics of Building Materials.*

Official NFPA Definitions

APPROVED: means “acceptable to the authority having jurisdiction.”

NOTE: The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment or materials nor does it approve or evaluate testing laboratories. In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization concerned with product evaluations which is in a position to determine compliance with appropriate standards for the current production of listed items.

AUTHORITY HAVING JURISDICTION: The “authority having jurisdiction” is the organization, office, or individual responsible for “approving” equipment, an installation, or a procedure.

NOTE: The phrase “authority having jurisdiction” is used in NFPA documents in a broad manner since jurisdictions and “approval” agencies vary as do their responsibilities. Where public safety is primary, the “authority having jurisdiction” may be a federal, state, local, or other regional department or individual such as a fire chief, fire marshal, chief of a fire prevention bureau, labor department, health department, building official, electrical inspector, or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the “authority having jurisdiction.” In many circumstances the property owner or his designated agent assumes the role of the “authority having jurisdiction”; at government installations, the commanding officer or departmental official may be the “authority having jurisdiction.”

LABELED: Equipment or materials to which has been attached a label, symbol or other identifying mark of an organization acceptable to the “authority having jurisdiction” and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

LISTED: Equipment or materials included in a list published by an organization acceptable to the “authority having jurisdiction” and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

NOTE: The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The “authority having jurisdiction” should utilize the system employed by the listing organization to identify a listed product.

SHALL: indicates a mandatory requirement.

SHOULD: indicates a recommendation or that which is advised but not required.